



CARTER WATKINS
ASSOCIATES
ARCHITECTS, INC.

DATE: OCTOBER 02, 2020
TO: ALL BIDDERS
RE: BURKE COUNTY JUDICIAL CENTER 911/EOC – AUDIO VISUAL EQUIPMENT

ADDENDUM #3

The following information provided in this Addendum shall supersede all information provided in the Construction Documents in regard to the affected items. This Addendum shall become part of the Construction Documents for the above project and shall be acknowledged by each bidder on the bid form.

1. Please note that Burke County sees no need for Document Cameras.
2. Please note that Burke County sees no need for Smart Boards in the Emergency Operations Center Room 105. Monitors, of equal size are suitable in Room 105. Provide Smart Boards in Meeting Rooms 106, 108, 109, 110 and Training Room 112.
3. Note that the word “Lectern” is used to refer to the Elmo Cart type equipment.
4. Monitors and smartboards need to be able to connect to laptops.
5. Provide one (1) microphone at each lectern.
6. Cable TV would be through RG6 and set top cable boxes would be provided by Cable TV provider. (Cable provider is most likely Comcast, however, there is a possibility of using an antenna for over-the-air TV.
7. Connection to County IT room would be by Coaxial, RG6.
8. Burke County does not require cameras in Dispatch Room 101.

END OF ADDENDUM